



STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

JOHN ELIAS BALDACCI
GOVERNOR

DAVID A. COLE
COMMISSIONER

July 27, 2009
Subject: **Southwest Harbor**
Maine Federal Aid Project No. 017611.00
State Pin No. 017611.00
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: Acadia National Park traditionally has always used RCP pipe for culverts. I do not see a pipe spec. anywhere in bid documents, does that mean any option of pipe under 603.031, Option III can be used?

Response: The existing pipes are corrugated metal pipes. The successful bidder will be allowed to use any of the option III pipes listed in the standard specifications in the 700 section.

Consider this information prior to submitting your bid on July 29, 2009.

Sincerely,

For

Scott Bickford
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER